PRINTED: 12/20/2010 FORM APPROVED

Bureau of Health Care Quality and Compliance

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION  (X1) PROVIDER/SUPPLIE IDENTIFICATION NU				(X2) MULTIPLE CONSTRUCTION			(X3) DATE SURVEY COMPLETED		
		IDENTIFICATION NOWB	LN.	A. BUILDING			C		
		NVS63AGZ		B. WING			30/2010		
				RESS, CITY, STA	TE, ZIP CODE				
4062 MG				HILL					
MONTHILL PALMS			LAS VEGAS, NV 89121						
(X4) ID	SUMMARY ST		ID	PROVIDER'S PLAN OF CORF		(X5)			
PREFIX TAG				PREFIX TAG	(EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		COMPLETE DATE		
IAG	neget nom on								
Y 000	Initial Comments		Y 000						
	The findings and conclusions of any investigation								
	by the Health Division shall not be construed as prohibiting any criminal or civil investigations, actions or other claims for relief that may be available to any party under applicable federal, state, or local laws.								
	This Statement of Deficiencies was generated as								
	a result of a required grading re-survey conducted in your facility on 11/30/10. This State Licensure survey was conducted by the authority of NRS 449.150, Powers of the Health Division. The facility received a re-survey grade of A.								
	The lability reserved a re-survey grade of A.								
	The facility is licensed for six Residential Facility								
	for Group beds for persons with Alzheimer's								
	disease, Category II residents. The census at the time of the survey was six. Six resident files were								
	reviewed and four employee files were reviewed.								
	The fellowing deficiencies were idealified.								
	The following deficiencies were identified:								
Y 353 SS=E	449.222(3) Bathrooms and Toilet Facilities			Y 353					
	NAO 440 000								
	NAC 449.222 3. The bottoms of tubs and showers must have								
	surfaces that inhibit falling and slipping. Cabinets								
	that are attached to the floor or grab bars must be								
	adjacent to the tubs, toilets and showers.								
	This Regulation is not met as evidenced by: Based on observation on 11/30/10, the facility								
	failed to ensure grab bars were provided adjacent								
	to the toilet in 1 of 3 bathrooms (bathroom located down the hall from the kitchen).								
	This was a repeat deficiency from the 7/20/10 state licensure survey.								

If deficiencies are cited, an approved plan of correction must be returned within 10 days after receipt of this statement of deficiencies.

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

PRINTED: 12/20/2010 FORM APPROVED

Bureau of Health Care Quality and Compliance

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:			PLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED			
		NIVOCA CZ		A. BUILDING  B. WING		C 11/30/2010			
NAME OF PR	ROVIDER OR SUPPLIER	NVS63AGZ	STREET ADDR	<b> </b> RESS, CITY, STA	ATE. ZIP CODE	11/3	0/2010		
MONTHIL			4062 MONTHILL LAS VEGAS, NV 89121						
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECT (EACH CORRECTIVE ACTION SHOU CROSS-REFERENCED TO THE APPRO DEFICIENCY)	LD BE	(X5) COMPLETE DATE		
Y 353	Continued From page 1			Y 353					
	Severity: 2 Scope: 2								

If deficiencies are cited, an approved plan of correction must be returned within 10 days after receipt of this statement of deficiencies.